



ADDENDUM #2

Date: October 3, 2024

Job No.: RFP 2024 – 05 Deep Retrofit Design

The following additions, deletions, and changes are to be read with and form part of the original Bid Document. Receipt of the addendum **is the responsibility of the bidder, all addendums made public.** This will serve to answer questions received, answer and changes are in red.

1. Deadline for issuing an Addendum is extended to October 3rd, 2024.
2. Submission deadline is extended to October 8th, 2024.
3. Is the entire building occupied? Yes the entire building is occupied and all work has to be performed with this in mind.
4. Are all units heated with baseboards? Yes, all units are heated with baseboards. The make up air system and DHW are heated with hydronic natural gas.
5. Please note that a "As Built Drawings" scan has been made available. Please send a request to the email below for this.

Email submissions only to: ddicaire@lanarkcounty.ca

Proponent's failure to submit their application by the closing date and time will result in their application no longer considered and will be returned unopened.